

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No- 03

Dated: 02.01.24

It is certified that an inspection team headed by Er. BRIJ MOHAN SINGH.....

(Name of Officers with designation) from ASSISTANCE ENGINEER (PHED)

(Name of Department/ Office) inspected the LAKSHYA INTERNATIONAL SCHOOL
MANUAPUL, GURWALIA BETTIAH W. CHAMPARAN(Name & Address of the school) on (date of inspection) and found that the
LAKSHYA INTERNATIONAL SCHOOL (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of ONE YEAR.....

Signature with Seal:
Aug 21/24

Name : सहायक अभियंता

Designation : लो० स्वा० अक० प्रकल्प
मकटिया

Name & Address of the Office / Department :

To

.....

.....

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report**

Format: I

Division Name: P.H. Division, Bettiah

Zone - Muzaffarpur
District Name: West Champaran

Sl. No.	Block	Panchayat	Village	Village code	Name of Habitation	Location of Source	Longitude	Parameters														Remarks				
								pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As		Total Coll			
1	2	3	4	5	6	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26		
1	CHAMPATIYA	GURWALIA	MANUWAPUL		MANUWAPUL	LAKSHYA INTERNATIONAL SCHOOL MANUWAPUL, GURWALIA BORING			7.8	1	350	210	150	48	9.6	20	150	0.10	BDL	25	NT	NT		NEGATIVE		
								Desirable Limit (mg/l)	6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.00	0.01	-	-		
								Permissible Limit* in absence of alternate source(mg/l)	NR	5.0	-	2000	600	200	100	1000	600	NR	400	NR	1.50	NR	**	-	-	-

Analyzed water sample conform to Indian standard under permissible limit for drinking purpose
Sample Collected by -SUNIL KUMAR JHA, LAKSHYA INTERNATIONAL SCHOOL, MANUWAPUL (BETTIAH)

Vijay Kumar
Chemist 02/01/2024
P.H. Division, Bettiah

Kumar
Assistant Engineer
P.H. Sub division, Narauliyaganaj

P.H. 1.27
Executive Engineer
P.H. Division, Bettiah