

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 05

Dated: 28/07/2025

It is certified that an inspection team headed byANIL KUMAR.....

(Name of Officers with designation) fromCHEMIST (PHED).....

(Name of Department/ Office) inspected the LAKSHYA INTERNATIONAL SCHOOL
MANUAPUL, GURWALIYA, BETTIAH, WEST CHAMPARAN(Name & Address of the school) on 28.07.2025 (date of inspection) and found that the
LAKSHYA INTERNATIONAL SCHOOL (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal: Anil Kr. 28/07/2025

Name

: ANIL KUMAR

Designation

: CHEMIST

Name & Address of the Office / Department :

To

LAKHYA International School
Manuapul, Gurwalya, Bettiah

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 25/07/2025 BY Mr. Sunil Kumar Jha & RECEIVED IN THE LABORATORY ON 25/07/2025

PARTICULARS OF THE SAMPLE					PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
Sl. NO	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
1.	Chanpatiya	Gurwatiya	Manuapal	LAKSHYA INTERNATIONAL SCHOOL Manuapal, Gurwatiya	0.94	7.3	324	128	136	32	11	19	10	0.2	0.0	0.2	216	NT	Neg.
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE

Remarks-- Analysed parameters of above sample is within permissible limit.

Signature of Analyst
Amal Kr.
28/07/2025
CHEMIST
DLWTL
 P.H. Division, Bettiah.